



(1) EC-TYPE EXAMINATION CERTIFICATE

- (2)Equipment or protective system intended for use in potentially explosive atmospheres -Directive 94/9/EC
- EC-Type Examination Certificate Number: KEMA 01ATEX1078 X (3)
- (4) Equipment or protective system: Reflex Radar Level Transmitter Model BM 100
- (5)Manufacturer: Krohne S.A.
- Address: Usine des Ors, 26103 Romans Cedex, France (6)
- This equipment or protective system and any acceptable variation thereto is specified in (7)the schedule to this certificate and the documents therein referred to.
- KEMA, notified body number 0344 in accordance with Article 9 of the Council Directive (8)94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential report no. 2010685.

Compliance with the Essential Health and Safety Requirements has been assured by (9)compliance with:

EN 50014: 1997 EN 50018: 2000 EN 50019: 2000 EN 50020: 1994 EN 50284: 1999 EN 50281-1-1: 1998

- If the sign "X" is placed after the certificate number, it indicates that the equipment or (10)protective system is subject to special conditions for safe use specified in the schedule to this certificate.
- (11)This EC-Type Examination Certificate relates only to the design, examination and tests of the specified equipment or protective system in accordance to the Directive 94/9/EC. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.
- The marking of the equipment or protective system shall include the following: (12)



II 1/2 GD T 75 °C ... 150 °C

EEx d [ia] IIC T6 ... T3 or EEx de [ia] IIC T6 ... T3 or EEx d [ia] IIB T6 ... T3 or EEx de [ia] IIB T6 ... T3

Arnhem, 1 August 2001 by order of the Board of Directors of N.V. KEMA

T. Piipker Certification Manager



This Certificate may only be reproduced in its entirety and without any change



SCHEDULE (13)

to EC-Type Examination Certificate KEMA 01ATEX1078 X (14)

Description (15)

Reflex Radar Level Transmitter Model BM 100 Type VF044 ... and Type SF049 ..., consisting of an aluminium enclosure, containing the electronics circuits, and a passive probe, is used to measure the level or the volume of a fluid or solid process medium inside a vessel or tank. The distance to the surface of the process medium is determined by the reflexion time of an electro-magnetic pulse, transmitted in the probe system. The measured pulse delay is converted into an electrical output signal.

There are variations in the probe type, material and length, in the process connection, in the mounting of the transmitter and in the nature of the electrical output signal.

For the application of the apparatus in a potentially explosive atmosphere caused by the presence of air/gas mixtures, the enclosure is in type of explosion protection flameproof enclosure "d". The terminal compartment is either in type of explosion protection flameproof enclosure "d" or in type of explosion protection increased safety "e".

For the application of the apparatus in a potentially explosive atmosphere caused by the presence of air/dust mixtures, the ingress protection of the enclosure is at least IP 65 in accordance with EN 60529.

Ambient temperature range at the transmitter enclosure -20 °C ... +50 °C.

Following tables show the relation between ambient temperature, temperature of the mounting flange respectively process temperature and temperature class:

Temperature class	Ambient temperature	ure Process temperature or temperature of mounting flang	
T6	≤ 50 °C	≤ 85 °C	
T5	≤ 50 °C	≤ 100 °C	
T4	≤ 50 °C	≤ 135 °C	
T3	≤ 50 °C	≤ 150 °C	

In temperature class T6, the temperature of the process medium may be higher than 85 °C, if the surface temperature at the mounting flange does not exceed 85 °C.

For use in a potentially explosive atmosphere caused by combustible dust, at a maximum ambient temperature of 50 °C, up to the maximum process temperature of 150 °C and with a dust layer of maximum 5 mm, the maximum surface temperature at any place of the apparatus is equal to the process temperature, but at least 75 °C.

Electrical data

 $U_N = 90...240 \text{ Vac } (\pm 10 \%) \text{ or}$ Supply 24 Vdc or ac (± 10 %), (terminals 11 and 12) $P_N = U_m =$ max. 8 W resp 10 VA

250 Vac

Output circuits depending on the signal modules used, the following (terminals 4.1, 4 and 6, 5 for all type of circuits) data apply to the intrinsically safe respectively the non-intrinsically safe signal output circuits:



(13)

SCHEDULE

(14) to EC-Type Examination Certificate KEMA 01ATEX1078 X

Electrical data (continued)

Intrinsically safe signal output circuits:

Active signal circuit in type of explosion protection intrinsic safety EEx ia IIC, with following maximum values:

$$U_o$$
 = 23,5 V I_o = 98 mA (linear characteristic) P_o = 0,6 W

Maximum allowed external inductance L_0 = 3,98 mH, maximum allowed external capacitance C_0 = 110 nF.

and/or

Passive signal circuit(s)
HART protocol optional

in type of explosion protection intrinsic safety EEx ia IIC, only for connection to a certified intrinsically safe circuit, with following maximum values:

$$U_i = 30 \text{ V}$$

 $I_i = 250 \text{ mA}$
 $P_i = 1 \text{ W}$

and/or

Fieldbus (PA or FF) in type of explosion protection intrinsic safety

EEx ia IIC, only for connection to a certified intrinsically safe circuit, with following maximum values:

$$U_i = 30 \text{ V}$$

 $I_i = 300 \text{ mA}$
 $P_i = 4.2 \text{ W}$

Of any intrinsically safe signal circuit, the effective internal capacitance C_i = 5 nF and the effective internal inductance L_i = 10 μ H.

The intrinsically safe circuits are infallibly galvanically isolated from the non-intrinsically safe circuits up to a peak value of the rated voltage of 375 V.

Non-intrinsically safe signal output circuits:

Active or passive circuits (HART, Fieldbus (PA or FF)
$$\begin{array}{cccc} U_N & \leq & 35 & V \\ I_N & \leq & 50 & mA \\ U_m & = & 250 & Vac \end{array}$$

Installation instructions

For the connection of the supply and signal cables, certified cable entries must be used, suitable for the application and properly installed.

In applications with a process temperature \geq 100 °C, the connected cables must be suitable for an operation temperature of at least 75 °C.



(13) SCHEDULE

(14) to EC-Type Examination Certificate KEMA 01ATEX1078 X

(16) Report

KEMA No. 2010685.

(17) Special conditions for safe use

- When the probe of a Level Transmitter is coated with a non-conductive layer, this
 probe may only be installed in a hazardous area where equipment category 1 G is
 required, under restriction of the apparatus group to IIB.
- The use of a Level Transmitter with a sensor with a non-conductive layer is not allowed in a potentially explosive atmosphere caused by combustible dust, unless precautions are taken to prevent electrostatic discharges. This must be pointed out to the user by means of a warning.
- The intrinsically safe Fieldbus (PA or FF) circuit is intended to be used in accordance with the FISCO model.
- The probe may only be installed in an area where an explosove mixture is present continuously or for long periods, if the explosive atmosphere is under atmospheric conditions (-20 °C ... + 60 °C and 80 ... 100 kPa).

(18) Essential Health and Safety Requirements

Essential Hea	alth and Safety Requirements not covered by the standards listed at (9)
Clause	Subject
1.0.5	Marking
1.0.6 b)	Instructions
2.1.2	Explosive atmospheres caused by air/dust mixtures

These Essential Health and Safety Requirements are examined and positively judged. The results are laid down in the report listed at (16)

(19) Test documentation

 EC-Type Examination Certificate PTB 01 ATEX 1047 U EC-Type Examination Certificate PTB 97 ATEX 2265 U

			signed
2.	Description (4	5 pages))
3.	Drawing No.	F08207512 05 F08207512 06 F08207512 07 F08207512 09 F08207512 10 F08207512 11 F08207512 12 F08207512 14 F08207512 16))))))))))



(13) SCHEDULE

(14) to EC-Type Examination Certificate KEMA 01ATEX1078 X

Test documentation (continued)

			signed
Drawing No.	F08207512 17 F08207512 18 F08207512 19 F08207512 22 F08207512 23 F08207512 24 F08207512 28 F08207512 31 F08207512 32 F08207512 32 F08207512 35 F08207512 35 F08207512 36 F08207512 37 F08207512 37 F08207512 39 F08207512 40 F08207512 41 F08207512 42 F08207512 43 F08207512 43		19.01.2001
	F08207512 70 F08207512 72 F08207512 77)	24.07.2001
	F08207512 74 F08207860 01 F08207860 02 F08207860 03 F08207860 04 F08207860 05 F08207860 06 F08207860 07 F08207860 09 F08207860 14 F08207860 15 F08207860 15 F08207860 20 F08207860 20 F08207860 21 F08207860 21 F08207860 22 F08207860 22 F08207860 23 F08207860 24 F08207860 30 F08207860 31 F08207860 32 F08207860 32 F08207860 33		19.01.2001

4. Samples