



Certificate of Compliance

Certificate: 1748096 (LR 105802)

Master Contract: 162767

Project: 2508314

Date Issued: April 12, 2012

Issued to: **KROHNE, Inc.**
7 Dearborn Rd
Peabody, MA 01960
USA
Attention: Rick Loiselle

The products listed below are eligible to bear the CSA Mark shown



Joe da Silva

Issued by: Joe da Silva, C.E.T.

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Gps. A, B, C and D; Cl. II, Gps. E, F and G; Cl. III:

Class I, Div. 2, Gps. A, B, C and D; Cl. II, Div. 2, F and G; Cl. III, Div. 2:

Variable area flowmeter Series H250a/ b /M10 consisting of H250 or H250C flowtube and M10 converter, rated input $24 \pm 30\%$ Vdc, 4–20 mA, operating ambient -40°C to 60°C ; Encl. Type 4X and 6; MWP 4,960 psi.,

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 0-M91 (R2001) - General Requirements - Canadian Electrical Code, Part II

CSA Std C22.2 No. 25-1966 - Enclosures for Use in Class II, Groups E, F and G Hazardous Locations

CSA Std C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations

CSA C22.2 No. 94-M91 (R2001) - Special Purpose Enclosures; Industrial Products

CSA Std C22.2 No. 142-M1987 - Process Control Equipment

CSA Std C22.2 No. 213-M1987 - Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

MARKINGS



Certificate: 1748096 (LR 105802)

Master Contract: 162767

Project: 2508314

Date Issued: April 12, 2012

- Submitter's Name
- Model Number
- Serial Number
- Electrical Rating
- Maximum Operating Pressure
- Operating Ambient
- Enclosure Type
- Hazardous Location Designation (Including the use of Zone designation)
- Warning Regarding Removing Cover While Circuits Are Alive